



R.Ravinder Reddy
Joint Chief Environmental Engineer (FAC)

H.No.6-3-1219, T.S.No.1, Part, Block "C",
Ward No.91, Begumpet, Umanagar,
Near Country Club, Hyderabad - 500 016
Email:hyd.zo.jcee@pcb.ap.gov.in

**CONSENT & AUTHORIZATION ORDER
BY REGISTERED POST WITH ACKNOWLEDGMENT DUE**

Consent Order No. 212-RR-II/TSPCB/ZOH/HCE/CFO/2015- 5863 Date:07.12.2015

(Consent Order for Existing/New or altered discharge of sewage and/or trade effluents/outlet under Section 25/26 of the Water (Prevention & Control of Pollution) Act, 1974 and amendments thereof and Operation of the plant under section 21 of Air (Prevention & Control of Pollution) Act, 1981 and amendments thereof) and Authorization / Renewal of Authorization under Rule 5 of the Hazardous Wastes (Management, Handling and Transboundary Movement) Rules, 2008& Amendments thereof.

CONSENT is hereby granted under section 25/26 of the Water (Prevention & Control of Pollution) Act, 1974 and under section 21 of Air (Prevention & Control of Pollution) Act, 1981 and Authorization under the provisions of HW (M,H&TM) Rules (hereinafter referred to as 'the Acts', 'the Rules') and the rules and orders made thereunder to

M/s. Malla Reddy Hospital,
Sy.No: 138, Main Road, Suraram,
Qutubullapur (M), Rangareddy District

(Hereinafter referred to as 'the Applicant') authorizing to operate the industrial plant, to discharge the effluents from the outlets and the quantity of emissions per hour from the chimneys as detailed below.

i) Outlets for discharge of effluents:

Outlet No.	Outlet Description	Max Daily Discharge	Point of Disposal	Limiting Standards
1.	Process & Washings	10.0 KLD	After disinfection, the washing effluents shall be further treated in common STP along with domestic effluents. After treatment in common STP, both Malla Reddy Hospital & Narayana Hrudayalaya Hospital (350 KLD) the treated effluents shall be discharged into Municipal Sewers, after meeting surface water standards.	pH - 5.5 - 9.0, Total Suspended Solids - 600.0 mg /l, Oil & Grease - 20.0 mg /l, Biochemical Oxygen Demand (3 days at 27 ⁰ C) - 30.0 mg /l
2.	Domestic	85.0 KLD		

ii) Emissions from chimneys:

Chimney No.	Description of Chimney	Quantity of Emissions at peak flow	Emission Standards
1.	Attached to DG set of capacity – 1 x 500 KVA	----	SPM - 115 mg/Nm ³
2	Attached to DG set of capacity – 1 x 250 KVA	----	

iii) Hazardous Waste Authorization: (Form – II) [See Rule 5(4)]:

M/s. Malla Reddy Hospital, Sy.No: 138, Main Road, Suraram, Qutubullapur (M), Rangareddy District is hereby granted an authorization to operate a facility for collection, reception, storage, transport and disposal of the following wastes with quantities as mentioned below:

Hazardous Waste with Recycling Option:

Sl. No.	Name of the Hazardous Waste	Stream	Quantity of Hazardous waste	Disposal Option
1.	Waste oil	5.1 of Sch- I	200 LPA	Shall be sent to authorized waste oil Re-Processors / Re-Cycling units.

This consent order is valid for the manufacture of the following products with quantities mentioned below only:

Sl. No.	Product & By Product	Quantity
1.	Hospital with bed strength	500 Nos.

This order is subject to the provisions of 'the Acts' and the Rules' and amendments made thereunder and further subject to the terms and conditions incorporated in the schedule A, B and C enclosed to this order.

This combined order of Consent and Authorization is valid for a period ending with the 31st Day of October, 2016

Handwritten signature and date: 17/10/2015
JOINT CHIEF ENVIRONMENTAL ENGINEER (FAC)

To
M/s. Malla Reddy Hospital,
Sy.No: 138, Main Road, Suraram,
Qutubullapur (M), Rangareddy District